



Technical Report No.: 64.181.24.00471.01 Rev.00

Date: 2024-06-25

Client: Name: Guangzhou Sprsun New Energy Technology Development Co., Ltd
Address: No.15 Tangxi Road, Yinsha Industrial Park, Xintang, Zengcheng District, Guangzhou, 511338, China
Contact person: YE XIN

Manufacturer: Name: Guangzhou Sprsun New Energy Technology Development Co., Ltd
Address: No.15 Tangxi Road, Yinsha Industrial Park, Xintang, Zengcheng District, Guangzhou, 511338, China

Factory: Name: Guangzhou Sprsun New Energy Technology Development Co., Ltd
Address: No.15 Tangxi Road, Yinsha Industrial Park, Xintang, Zengcheng District, Guangzhou, 511338, China

Test object: Product: DC Inverter Air Source Heat Pumps
Model: CGK-030V4P-B, CGK-040V4P-B, CGK-050V4P-B

Trade mark:

Test specification: EN 14825:2022
 EN 14511-3:2022
 EN 12102-1:2022
 EN 14511-4:2022 Clause 4

Purpose of examination: Test according to the test specification
 (EU) No 813/2013
 EU 2016/2282:2016-11-30

Test result: The test results show that the presented product is in compliance with the above listed test specifications.

Any use for advertising purposes must be granted in writing. This technical report may only be quoted in full. This report is the result of a single examination of the object in question. It does not imply a general statement regarding the quality of products from regular production. For further details please see Testing, Certification, Validation and Verification Regulations, chapter A-3.3.

Doc No.: ITC-TTW0902.02E – Rev.15

1 Description of the test object

1.1 Function

Manufacturer's specification for intended use:
 These appliances are air to water heat pump.
 Manufacturer's specification for predictive use:
 According to user manual

1.2 Consideration of the foreseeable use

- Not applicable
- Covered through the applied standard
- Covered by the following comment
- Covered by attached risk analysis

1.3 Technical Data

Model :	CGK-030V4P-B, CGK-040V4P-B, CGK-050V4P-B		
Rated Voltage (V) :	380-420V, 3N~		
Rated Frequency (Hz) :	50		
Rated Power (W) :	see the nameplate		
Rated Current (A) :	see the nameplate		
Protection Class :	Class I		
Protection Against Moisture :	IP X4		
Construction :	Stationary		
Supply connection :	<input type="checkbox"/> Non detachable cord <input checked="" type="checkbox"/> Permanent connection to fixed wiring		
Operation mode:	<input checked="" type="checkbox"/> Continuous operation; <input type="checkbox"/> Intermittent operation; <input type="checkbox"/> Short time operation;		
Refrigerant/charge (kg) :	R290 / 0.75kg for CGK-030V4P-B, 0.90kg for CGK-040V4P-B, 1.20kg for CGK-050V4P-B		
Declared parameters :	<input checked="" type="checkbox"/> Average	<input type="checkbox"/> Warmer	<input type="checkbox"/> Colder
Sound power level dB(A) :	N/A		
Series No :	KBM053211000200013 for CGK-030V4P-B, KBM053211000600014 for CGK-040V4P-B, KBM053211000400015 for CGK-050V4P-B		

2 Order

2.1 Date of Purchase Order, Customer's Reference

Date of Purchase Order: 2023-06-21

Customer's Reference: Guangzhou Sprsun New Energy Technology Development Co., Ltd

2.2 Test Sample(s)

• Reception date(s): 2024-01-19

• Location(s) of reception:

For Energy test:

Guangzhou Customs District Technology Center
(CNAS accredited laboratory with Registration No.CNAS L2322)

Address: No.3, Desheng East Road, Daliang, Shunde District, Foshan, Guangdong, China

For Noise tests:

CVC Testing Technology Co., Ltd.
(CNAS accredited laboratory with Registration No.CNAS L0095)

Address: No.3, Tiantai Yilu, Kaitai Avenue, Science City, Guangzhou, Guangdong, China

• Condition of test sample(s): completed and can be normal operation

2.3 Date(s) of Testing

2024-01-19 to 2024-06-12

2.4 Location(s) of Testing

Same as 2.2

2.5 Points of Non-compliance or Exceptions of the Test Procedure

N/A

3 Test Results

Decision rule according to ILAC-G8:09/2019 clause 4.2.1 Binary statement for simple acceptance rule or IEC Guide 115:2023, clause 4.3 Simple acceptance was applied.

Decision rule according to customer's requirements was applied. It is:

Decision rule according to ILAC-G8:09/2019 clause 4.2.2 Binary statement with guard band - guard band length = 95 % extended measurement uncertainty, was applied.

Decision rule (based on ILAC-G8:09/2019 clause 4.2.3 Non-binary statement with guard band, guard band length = 95 % extended measurement uncertainty) for an upper specification limit (A lower limit or specification with an up-per and a lower limit is treated similarly.):

• Compliance with the requirement: If a specification limit is not breached by a measurement result plus the expanded uncertainty with a 95% coverage probability, then compliance with the specification will be stated (e. g. Pass).

• Non-compliance with the requirement: If a specification limit is exceeded by the measurement result minus the expanded uncertainty with a 95% coverage probability, then non-compliance with the specification will be stated (e. g. Fail).

• Inconclusive result: If a measurement result plus/minus the expanded uncertainty with a 95 % coverage probability overlaps the limit it will be stated that it is not possible to state compliance or non-compliance.

There are no statements to conformity or no results with measurand stated in this report, no decision rule has been applied.



3.1 Positive Test Results

See Appendix I

4 Remarks

4.1 General

The user manual has been examined according to the minimum requirements described in the product standard. The manufacturer is responsible for the accuracy of further particulars as well as of the composition and layout.

4.2 When the product is placed on the market, it must be accompanied with safety Instructions written in official language of the country. The instructions shall give information regarding safe operation, installation and maintenance.

5 Documentation

- Appendix I: Test results
- Appendix II: Marking plate
- Appendix III: photo documentation
- Appendix IV: Construction data form
- Appendix V: Test equipment list

6 Test History

- 1) These appliances are Air To Water Heat Pump Unit, each one including a whole compression type refrigerant circuit to heat water in another circuit. These appliances were for cooling and heating water function, this report only for heating capacity test.
- 2) The main power is supplied by a 5-pole supply cord connecting to fixed wiring.
- 3) Water enthalpy method was adopted in this report.
- 4) Standby mode power, off mode power and thermostat-off mode power were tested according to clause 12 of standard EN 14825:2022.

Doc No.: ITC-TTW0902.02E – Rev.15

**TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch
TÜV SÜD Group**

Tested by: William Liang, Project Handler

printed name, function & signature

Approved by: Plum Li, Designated Reviewer

printed name, function & signature



Appendix I Test results

Table 1.	Heating mode (Low temperature application):						P	
Model	CGK-030V4P-B							
Product type	Air to Water	Heating season	<input checked="" type="checkbox"/>	Average	<input type="checkbox"/>	Warmer	<input type="checkbox"/>	Colder
1. Test conditions:								
Condition	Part Load Ratio in %		Outdoor heat exchanger		Indoor heat exchanger			
	Formula	Average climates	Inlet dry (wet) bulb temperature (°C)		Inlet/outlet water temperatures (°C)			
A	$(-7-16)/(T_{designh-16})$	88	-7(-8)		a / 34			
B	$(+2-16)/(T_{designh-16})$	54	2(1)		a / 30			
C	$(+7-16)/(T_{designh-16})$	35	7(6)		a / 27			
D	$(+12-16)/(T_{designh-16})$	15	12(11)		a / 24			
E	$(TOL-16)/(T_{designh-16})$		TOL		a / 35.3			
F	$(T_{bivalent-16})/(T_{designh-16})$		T _{biv}		a / 34			
G	$(-15-16)/(T_{designh-16})$	N/A	-15		N/A			
Remark: a) With the water flow rate as determined at the standard rating conditions given in EN14511-2 at 30/35 conditions, the capacity is 5.732kW, the power is 1.180kW, the COP is 4.86kW/kW.								
2. Tested data/correction data(Average):								
General test conditions/ Part-Load	Unit	A(-7)/W34 (88%)	A2/W30 (54%)	A7/W27 (35%)	A12/W24 (15%)	A(-10)/W35.3 (100%)	A(-7)/ W34 (88%)	
	--	A	B	C	D	E	F	
Data collection period	hh: min:sec	1:10:00	1:10:00	1:10:00	1:10:00	1:10:00	1:10:00	
The heat pump defrosts	--	No	No	No	No	No	No	
Electrical Properties								
Voltage	V	399.8	399.8	399.5	399.3	400.6	399.8	
Current input of the unit	A	3.42	1.49	1.06	0.98	3.50	3.42	
Power input of the unit	kW	1.913	0.775	0.537	0.491	2.040	1.913	
Compressor frequency	Hz	85	38	30	30	90	85	

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix I Test results

Test conditions User Side							
Water flow	m³/h	1.00	1.00	1.00	1.00	1.00	1.00
Inlet Water temperature	°C	28.86	26.87	24.97	23.18	30.21	28.86
Outlet Water temperature	°C	33.96	29.99	27.76	26.33	35.19	33.96
Test conditions Source Side							
Barometric pressure	kPa	101.02	101.01	101.01	101.02	101.01	101.02
Air inlet temperature, DB	°C	-6.99	2.01	6.93	12.06	-10.06	-6.99
Air inlet temperature, WB	°C	-7.99	1.00	6.03	10.95	-10.98	-7.99
Summary of the results							
Total heating capacity	kW	5.927	3.609	3.237	3.651	5.795	5.927
Effective power input	kW	1.912	0.764	0.528	0.480	2.039	1.912
Coefficient of performance (COP)	kW/kW	3.10	4.73	6.13	7.61	2.84	3.10
Remark: -							

Electric power consumptions	Unit	Value
Thermostat-off mode [P _{TO}]	kW	0.045
Standby mode [P _{SB}]	kW	0.022
Crankcase heater [P _{CK}]	kW	0.039
Off mode [P _{OFF}]	kW	0.022

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix I Test results

3.Calculation/conclusion for SCOP:						
Tdesignh(°C):	-10	Tbiv(°C) :	-7			
Pdesignh(kW):	6.701	TOL(°C) :	-10			
Test result A, B, C, D, E, F conditions:						
Condition	Part load	Measured capacity	Measured COP	Cdh	CR	COP at part load
E	6.701	5.795	2.84	0.90	1.00	2.84
F	5.927	5.927	3.10	0.90	1.00	3.10
A	5.927	5.927	3.10	0.90	1.00	3.10
B	3.608	3.609	4.73	0.90	1.00	4.73
C	2.319	3.237	6.13	0.90	0.72	5.90
D	1.031	3.651	7.61	0.90	0.28	6.07
CR: part load divided by capacity;						

Conclusions:	Unit	Value
SCOPon:	kWh/kWh	4.70
SCOP:	kWh/kWh	4.68
Q _H :	kWh/year	13843
Q _{HE} :	kWh/year	2957
η _{s,h}	%	184.2
Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 2)	--	A+++

Appendix I Test results

Table 2.	Heating mode (Medium temperature application):						P	
Model	CGK-030V4P-B							
Product type	Air to Water	Heating season	<input checked="" type="checkbox"/>	Average	<input type="checkbox"/>	Warmer	<input type="checkbox"/>	Colder
1. Test conditions:								
Condition	Part Load Ratio in %		Outdoor heat exchanger		Indoor heat exchanger			
	Formula	Average climates	Inlet dry (wet) bulb temperature (°C)		Inlet/outlet water temperatures (°C)			
A	$(-7-16)/(T_{designh-16})$	88	-7(-8)		a / 52			
B	$(+2-16)/(T_{designh-16})$	54	2(1)		a / 42			
C	$(+7-16)/(T_{designh-16})$	35	7(6)		a / 36			
D	$(+12-16)/(T_{designh-16})$	15	12(11)		a / 30			
E	$(TOL-16)/(T_{designh-16})$		TOL		a / 55.3			
F	$(T_{bivalent-16})/(T_{designh-16})$		T _{biv}		a / 52			
G	$(-15-16)/(T_{designh-16})$	N/A	-15		N/A			
Remark: a) With the water flow rate as determined at the standard rating conditions given in EN14511-2 at 47/55 conditions, the capacity is 6.297kW, the power is 1.957kW, the COP is 3.22kW/kW.								
2. Tested data/correction data(Average):								
General test conditions/ Part-Load	Unit	A(-7)/W52 (88%)	A2/W42 (54%)	A7/W36 (35%)	A12/W30 (15%)	A(-10)/W55.3 (100%)	A(-7)/ W52 (88%)	
	--	A	B	C	D	E	F	
Data collection period	hh: min:sec	1:10:00	1:10:00	1:10:00	1:10:00	1:10:00	1:10:00	
The heat pump defrosts	--	No	No	No	No	No	No	
Electrical Properties								
Voltage	V	399.6	399.8	399.3	399.3	399.2	399.6	
Current input of the unit	A	4.05	1.78	1.26	1.16	4.17	4.05	
Power input of the unit	kW	2.340	0.935	0.647	0.581	2.508	2.340	
Compressor frequency	Hz	85	38	30	30	90	85	

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix I Test results

Test conditions User Side							
Water flow	m³/h	0.70	0.70	0.70	0.70	0.70	0.70
Inlet Water temperature	°C	45.32	37.73	33.47	29.03	48.41	45.32
Outlet Water temperature	°C	52.09	41.93	37.28	33.38	55.09	52.09
Test conditions Source Side							
Barometric pressure	kPa	99.85	99.85	99.85	99.80	99.75	99.85
Air inlet temperature, DB	°C	-7.00	1.97	6.98	11.99	-9.95	-7.00
Air inlet temperature, WB	°C	-7.99	0.99	6.05	11.07	-11.05	-7.99
Summary of the results							
Total heating capacity	kW	5.509	3.401	3.097	3.534	5.439	5.509
Effective power input	kW	2.340	0.921	0.635	0.570	2.508	2.340
Coefficient of performance (COP)	kW/kW	2.35	3.69	4.88	6.20	2.17	2.35
Remark: -							

Electric power consumptions	Unit	Value
Thermostat-off mode [P _{TO}]	kW	0.045
Standby mode [P _{SB}]	kW	0.022
Crankcase heater [P _{CK}]	kW	0.039
Off mode [P _{OFF}]	kW	0.022

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix I Test results

3.Calculation/conclusion for SCOP:						
Tdesignh(°C):	-10	Tbiv(°C) :	-7			
Pdesignh(kW):	6.228	TOL(°C) :	-10			
Test result A, B, C, D, E, F conditions:						
Condition	Part load	Measured capacity	Measured COP	Cdh	CR	COP at part load
E	6.228	5.439	2.17	0.90	1.00	2.17
F	5.509	5.509	2.35	0.90	1.00	2.35
A	5.509	5.509	2.35	0.90	1.00	2.35
B	3.353	3.401	3.69	0.90	0.99	3.69
C	2.156	3.097	4.88	0.90	0.70	4.68
D	0.958	3.534	6.20	0.90	0.27	4.89
CR: part load divided by capacity;						

Conclusions:	Unit	Value
SCOPon:	kWh/kWh	3.68
SCOP:	kWh/kWh	3.67
QH:	kWh/year	12866
QHE:	kWh/year	3507
$\eta_{s,h}$	%	143.8
Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 1)	--	A++

Appendix I Test results

Table 3.	Heating mode (Low temperature application):						P	
Model	CGK-040V4P-B							
Product type	Air to Water	Heating season	<input checked="" type="checkbox"/>	Average	<input type="checkbox"/>	Warmer	<input type="checkbox"/>	Colder
1. Test conditions:								
Condition	Part Load Ratio in %		Outdoor heat exchanger		Indoor heat exchanger			
	Formula	Average climates	Inlet dry (wet) bulb temperature (°C)		Inlet/outlet water temperatures (°C)			
A	$(-7-16)/(T_{designh-16})$	88	-7(-8)		a / 34			
B	$(+2-16)/(T_{designh-16})$	54	2(1)		a / 30			
C	$(+7-16)/(T_{designh-16})$	35	7(6)		a / 27			
D	$(+12-16)/(T_{designh-16})$	15	12(11)		a / 24			
E	$(TOL-16)/(T_{designh-16})$		TOL		a / 35.3			
F	$(T_{bivalent-16})/(T_{designh-16})$		T _{biv}		a / 34			
G	$(-15-16)/(T_{designh-16})$	N/A	-15		N/A			
Remark: a) With the water flow rate as determined at the standard rating conditions given in EN14511-2 at 30/35 conditions, the capacity is 7.650kW, the power is 1.577kW, the COP is 4.85kW/kW.								
2. Tested data/correction data(Average):								
General test conditions/ Part-Load	Unit	A(-7)/W34 (88%)	A2/W30 (54%)	A7/W27 (35%)	A12/W24 (15%)	A(-10)/W35.3 (100%)	A(-7)/ W34 (88%)	
	--	A	B	C	D	E	F	
Data collection period	hh: min:sec	1:10:00	1:10:00	1:10:00	1:10:00	1:10:00	1:10:00	
The heat pump defrosts	--	No	No	No	No	No	No	
Electrical Properties								
Voltage	V	400.0	400.5	400.5	400.7	399.6	400.0	
Current input of the unit	A	4.36	1.89	1.35	1.24	4.49	4.36	
Power input of the unit	kW	2.575	1.005	0.707	0.636	2.734	2.575	
Compressor frequency	Hz	85	38	30	30	90	85	

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix I Test results

Test conditions User Side							
Water flow	m³/h	1.35	1.35	1.35	1.35	1.35	1.35
Inlet Water temperature	°C	29.00	26.82	25.06	23.24	30.43	29.00
Outlet Water temperature	°C	33.99	29.87	27.92	26.48	35.27	33.99
Test conditions Source Side							
Barometric pressure	kPa	101.02	101.01	101.01	101.02	101.01	101.02
Air inlet temperature, DB	°C	-6.99	2.03	7.06	11.89	-10.10	-6.99
Air inlet temperature, WB	°C	-8.05	1.00	5.91	10.98	-10.98	-8.05
Summary of the results							
Total heating capacity	kW	7.832	4.774	4.483	5.066	7.600	7.832
Effective power input	kW	2.574	0.994	0.698	0.620	2.733	2.574
Coefficient of performance (COP)	kW/kW	3.04	4.80	6.43	8.17	2.78	3.04
Remark: -							

Electric power consumptions	Unit	Value
Thermostat-off mode [P _{TO}]	kW	0.046
Standby mode [P _{SB}]	kW	0.023
Crankcase heater [P _{CK}]	kW	0.038
Off mode [P _{OFF}]	kW	0.023

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix I Test results

3.Calculation/conclusion for SCOP:						
Tdesignh(°C):	-10	Tbiv(°C) :	-7			
Pdesignh(kW):	8.854	TOL(°C) :	-10			
Test result A, B, C, D, E, F conditions:						
Condition	Part load	Measured capacity	Measured COP	Cdh	CR	COP at part load
E	8.854	7.600	2.78	0.90	1.00	2.78
F	7.832	7.832	3.04	0.90	1.00	3.04
A	7.832	7.832	3.04	0.90	1.00	3.04
B	4.767	4.774	4.80	0.90	1.00	4.80
C	3.065	4.483	6.43	0.90	0.68	6.14
D	1.362	5.066	8.17	0.90	0.27	6.42
CR: part load divided by capacity;						

Conclusions:	Unit	Value
SCOPon:	kWh/kWh	4.79
SCOP:	kWh/kWh	4.77
Q _H :	kWh/year	18292
Q _{HE} :	kWh/year	3833
η _{s,h}	%	187.9
Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 2)	--	A+++

Appendix I Test results

Table 4.	Heating mode (Medium temperature application):						P	
Model	CGK-040V4P-B							
Product type	Air to Water	Heating season	<input checked="" type="checkbox"/>	Average	<input type="checkbox"/>	Warmer	<input type="checkbox"/>	Colder
1. Test conditions:								
Condition	Part Load Ratio in %		Outdoor heat exchanger		Indoor heat exchanger			
	Formula	Average climates	Inlet dry (wet) bulb temperature (°C)		Inlet/outlet water temperatures (°C)			
A	$(-7-16)/(T_{designh-16})$	88	-7(-8)		a / 52			
B	$(+2-16)/(T_{designh-16})$	54	2(1)		a / 42			
C	$(+7-16)/(T_{designh-16})$	35	7(6)		a / 36			
D	$(+12-16)/(T_{designh-16})$	15	12(11)		a / 30			
E	$(TOL-16)/(T_{designh-16})$		TOL		a / 55.3			
F	$(T_{bivalent-16})/(T_{designh-16})$		T _{biv}		a / 52			
G	$(-15-16)/(T_{designh-16})$	N/A	-15		N/A			
Remark: a) With the water flow rate as determined at the standard rating conditions given in EN14511-2 at 47/55 conditions, the capacity is 9.058kW, the power is 2.904kW, the COP is 3.12kW/kW.								
2. Tested data/correction data(Average):								
General test conditions/ Part-Load	Unit	A(-7)/W52 (88%)	A2/W42 (54%)	A7/W36 (35%)	A12/W30 (15%)	A(-10)/ W55.3 (100%)	A(-7)/ W52 (88%)	
	--	A	B	C	D	E	F	
Data collection period	hh: min:sec	1:10:00	1:10:00	1:10:00	1:10:00	1:10:00	1:10:00	
The heat pump defrosts	--	No	No	No	No	No	No	
Electrical Properties								
Voltage	V	399.2	400.2	400.4	400.5	399.1	399.2	
Current input of the unit	A	5.20	2.41	1.65	1.46	5.56	5.20	
Power input of the unit	kW	3.221	1.339	0.876	0.758	3.465	3.221	
Compressor frequency	Hz	85	38	30	30	90	85	

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix I Test results

Test conditions User Side							
Water flow	m ³ /h	1.00	1.00	1.00	1.00	1.00	1.00
Inlet Water temperature	°C	45.56	37.83	33.47	28.85	48.91	45.56
Outlet Water temperature	°C	51.97	42.00	37.14	33.04	55.08	51.97
Test conditions Source Side							
Barometric pressure	kPa	99.85	99.85	99.85	99.80	99.75	99.85
Air inlet temperature, DB	°C	-7.00	2.00	6.93	12.08	-10.12	-7.00
Air inlet temperature, WB	°C	-8.00	1.00	5.99	11.02	-10.97	-8.00
Summary of the results							
Total heating capacity	kW	7.454	4.857	4.266	4.873	7.168	7.454
Effective power input	kW	3.217	1.335	0.873	0.755	3.462	3.217
Coefficient of performance (COP)	kW/kW	2.32	3.64	4.88	6.45	2.07	2.32
Remark: -							

Electric power consumptions	Unit	Value
Thermostat-off mode [P _{TO}]	kW	0.046
Standby mode [P _{SB}]	kW	0.023
Crankcase heater [P _{CK}]	kW	0.038
Off mode [P _{OFF}]	kW	0.023

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix I Test results

3.Calculation/conclusion for SCOP:						
Tdesignh(°C):	-10	Tbiv(°C) :	-7			
Pdesignh(kW):	8.426	TOL(°C) :	-10			
Test result A, B, C, D, E, F conditions:						
Condition	Part load	Measured capacity	Measured COP	Cdh	CR	COP at part load
E	8.426	7.168	2.07	0.90	1.00	2.07
F	7.454	7.454	2.32	0.90	1.00	2.32
A	7.454	7.454	2.32	0.90	1.00	2.32
B	4.537	4.857	3.64	0.90	0.93	3.64
C	2.917	4.266	4.88	0.90	0.68	4.67
D	1.296	4.873	6.45	0.90	0.27	5.06
CR: part load divided by capacity;						

Conclusions:	Unit	Value
SCOPon:	kWh/kWh	3.65
SCOP:	kWh/kWh	3.64
QH:	kWh/year	17408
QHE:	kWh/year	4783
$\eta_{s,h}$	%	142.6
Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 1)	--	A++

Appendix I Test results

Table 5.	Heating mode (Low temperature application):						P	
Model	CGK-050V4P-B							
Product type	Air to Water	Heating season	<input checked="" type="checkbox"/>	Average	<input type="checkbox"/>	Warmer	<input type="checkbox"/>	Colder
1. Test conditions:								
Condition	Part Load Ratio in %		Outdoor heat exchanger		Indoor heat exchanger			
	Formula	Average climates	Inlet dry (wet) bulb temperature (°C)		Inlet/outlet water temperatures (°C)			
A	$(-7-16)/(T_{designh-16})$	88	-7(-8)		a / 34			
B	$(+2-16)/(T_{designh-16})$	54	2(1)		a / 30			
C	$(+7-16)/(T_{designh-16})$	35	7(6)		a / 27			
D	$(+12-16)/(T_{designh-16})$	15	12(11)		a / 24			
E	$(TOL-16)/(T_{designh-16})$		TOL		a / 35.3			
F	$(T_{bivalent-16})/(T_{designh-16})$		T _{biv}		a / 34			
G	$(-15-16)/(T_{designh-16})$	N/A	-15		N/A			
Remark: a) With the water flow rate as determined at the standard rating conditions given in EN14511-2 at 30/35 conditions, the capacity is 10.279kW, the power is 2.095kW, the COP is 4.91kW/kW.								
2. Tested data/correction data(Average):								
General test conditions/ Part-Load	Unit	A(-7)/W34 (88%)	A2/W30 (54%)	A7/W27 (35%)	A12/W24 (15%)	A(-10)/W35.3 (100%)	A(-7)/ W34 (88%)	
	--	A	B	C	D	E	F	
Data collection period	hh: min:sec	1:10:00	1:10:00	1:10:00	1:10:00	1:10:00	1:10:00	
The heat pump defrosts	--	No	No	No	No	No	No	
Electrical Properties								
Voltage	V	399.6	400.3	400.5	400.7	399.2	399.6	
Current input of the unit	A	5.69	2.56	1.76	1.61	5.97	5.69	
Power input of the unit	kW	3.504	1.409	0.949	0.854	3.743	3.504	
Compressor frequency	Hz	85	40	30	30	90	85	

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix I Test results

Test conditions User Side							
Water flow	m³/h	1.75	1.75	1.75	1.75	1.75	1.75
Inlet Water temperature	°C	28.45	26.62	25.09	23.01	30.09	28.45
Outlet Water temperature	°C	33.88	29.95	28.00	26.33	35.38	33.88
Test conditions Source Side							
Barometric pressure	kPa	101.02	101.01	101.01	101.02	101.01	101.02
Air inlet temperature, DB	°C	-6.99	2.01	7.07	11.89	-9.98	-6.99
Air inlet temperature, WB	°C	-8.06	1.00	5.92	10.92	-10.97	-8.06
Summary of the results							
Total heating capacity	kW	11.043	6.766	5.924	6.737	10.779	11.043
Effective power input	kW	3.502	1.398	0.941	0.845	3.742	3.502
Coefficient of performance (COP)	kW/kW	3.15	4.84	6.30	7.97	2.88	3.15
Remark: -							

Electric power consumptions	Unit	Value
Thermostat-off mode [P _{TO}]	kW	0.085
Standby mode [P _{SB}]	kW	0.024
Crankcase heater [P _{CK}]	kW	0.041
Off mode [P _{OFF}]	kW	0.024

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix I Test results

3.Calculation/conclusion for SCOP:						
Tdesignh(°C):	-10	Tbiv(°C) :	-7			
Pdesignh(kW):	12.483	TOL(°C) :	-10			
Test result A, B, C, D, E, F conditions:						
Condition	Part load	Measured capacity	Measured COP	Cdh	CR	COP at part load
E	12.483	10.779	2.88	0.90	1.00	2.88
F	11.043	11.043	3.15	0.90	1.00	3.15
A	11.043	11.043	3.15	0.90	1.00	3.15
B	6.722	6.766	4.84	0.90	0.99	4.84
C	4.321	5.924	6.30	0.90	0.73	6.07
D	1.920	6.737	7.97	0.90	0.29	6.38
CR: part load divided by capacity;						

Conclusions:	Unit	Value
SCOPon:	kWh/kWh	4.83
SCOP:	kWh/kWh	4.81
Q _H :	kWh/year	25790
Q _{HE} :	kWh/year	5366
η _{s,h}	%	189.3
Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 2)	--	A+++

Appendix I Test results

Table 6.	Heating mode (Medium temperature application):						P	
Model	CGK-050V4P-B							
Product type	Air to Water	Heating season	<input checked="" type="checkbox"/>	Average	<input type="checkbox"/>	Warmer	<input type="checkbox"/>	Colder
1. Test conditions:								
Condition	Part Load Ratio in %		Outdoor heat exchanger		Indoor heat exchanger			
	Formula	Average climates	Inlet dry (wet) bulb temperature (°C)		Inlet/outlet water temperatures (°C)			
A	$(-7-16)/(T_{designh-16})$	88	-7(-8)		a / 52			
B	$(+2-16)/(T_{designh-16})$	54	2(1)		a / 42			
C	$(+7-16)/(T_{designh-16})$	35	7(6)		a / 36			
D	$(+12-16)/(T_{designh-16})$	15	12(11)		a / 30			
E	$(TOL-16)/(T_{designh-16})$		TOL		a / 55.3			
F	$(T_{bivalent-16})/(T_{designh-16})$		T _{biv}		a / 52			
G	$(-15-16)/(T_{designh-16})$	N/A	-15		N/A			
Remark: a) With the water flow rate as determined at the standard rating conditions given in EN14511-2 at 47/55 conditions, the capacity is 11.457kW, the power is 3.805kW, the COP is 3.01kW/kW.								
2. Tested data/correction data(Average):								
General test conditions/ Part-Load	Unit	A(-7)/W52 (88%)	A2/W42 (54%)	A7/W36 (35%)	A12/W30 (15%)	A(-10)/W55.3 (100%)	A(-7)/ W52 (88%)	
	--	A	B	C	D	E	F	
Data collection period	hh: min:sec	1:10:00	1:10:00	1:10:00	1:10:00	1:10:00	1:10:00	
The heat pump defrosts	--	No	No	No	No	No	No	
Electrical Properties								
Voltage	V	399.4	400.2	400.4	400.6	398.8	399.4	
Current input of the unit	A	6.76	3.13	2.15	1.92	7.17	6.76	
Power input of the unit	kW	4.248	1.746	1.183	1.032	4.558	4.248	
Compressor frequency	Hz	85	40	30	30	90	85	

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix I Test results

Test conditions User Side							
Water flow	m ³ /h	1.25	1.25	1.25	1.25	1.25	1.25
Inlet Water temperature	°C	44.76	37.55	33.34	28.81	48.31	44.76
Outlet Water temperature	°C	51.91	41.97	37.19	33.28	55.24	51.91
Test conditions Source Side							
Barometric pressure	kPa	99.85	99.85	99.85	99.80	99.75	99.85
Air inlet temperature, DB	°C	-7.00	2.08	6.99	11.99	-9.94	-7.00
Air inlet temperature, WB	°C	-8.06	1.00	5.98	11.12	-11.04	-8.06
Summary of the results							
Total heating capacity	kW	10.392	6.408	5.577	6.477	10.074	10.392
Effective power input	kW	4.246	1.726	1.163	1.013	4.557	4.246
Coefficient of performance (COP)	kW/kW	2.45	3.71	4.80	6.39	2.21	2.45
Remark: -							

Electric power consumptions	Unit	Value
Thermostat-off mode [P _{TO}]	kW	0.085
Standby mode [P _{SB}]	kW	0.024
Crankcase heater [P _{CK}]	kW	0.041
Off mode [P _{OFF}]	kW	0.024

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix I Test results

3.Calculation/conclusion for SCOP:						
Tdesignh(°C):	-10	Tbiv(°C) :	-7			
Pdesignh(kW):	11.747	TOL(°C) :	-10			
Test result A, B, C, D, E, F conditions:						
Condition	Part load	Measured capacity	Measured COP	Cdh	CR	COP at part load
E	11.747	10.074	2.21	0.90	1.00	2.21
F	10.392	10.392	2.45	0.90	1.00	2.45
A	10.392	10.392	2.45	0.90	1.00	2.45
B	6.326	6.408	3.71	0.90	0.99	3.71
C	4.066	5.577	4.80	0.90	0.73	4.62
D	1.807	6.477	6.39	0.90	0.28	5.08
CR: part load divided by capacity;						

Conclusions:	Unit	Value
SCOPon:	kWh/kWh	3.72
SCOP:	kWh/kWh	3.71
QH:	kWh/year	24270
QHE:	kWh/year	6547
$\eta_{s,h}$	%	145.3
Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 1)	--	A++

Appendix I Test results

Table 7a.	Sound power level measurement (Low temperature application)		P
Model	CGK-030V4P-B		
	Product type :	Air to Water	
	Outdoor heat exchanger, Air temperature DB/WB (°C):	7.0 / 6.0	
	Indoor heat exchanger, Water outlet temperature (°C):	35.0	
	Voltage (V):	400	
	Frequency (Hz):	50	
	Working condition class :	Class A	
	Acoustical environment :	Hemi-anechoic room	
	Windshield type :	Sponge	
	Measured position amount :	14	
Measured quantity	L _{WA,indoors} (dB(A))	L _{WA,outdoors} (dB(A))	Remark
Sound pressure level ` L _{p(ST)} ****	--	40	--
Measurement distance d *	--	1.0m	--
Sound power level L _{WA} ****	--	54	--
Setting of controls: according to user manual.			
Duct connection:--			
Rounding to: *) 1 decimal places; **) 2 decimal places; ***) 3 decimal places; ****) nearest integer			

Appendix I Test results

Table 7b.	Sound power level measurement (Medium temperature application)		P
Model	CGK-030V4P-B		
	Product type :	Air to Water	
	Outdoor heat exchanger, Air temperature DB/WB (°C):	7.0 / 6.0	
	Indoor heat exchanger, Water outlet temperature (°C):	55.0	
	Voltage (V):	400	
	Frequency (Hz):	50	
	Working condition class :	Class A	
	Acoustical environment :	Hemi-anechoic room	
	Windshield type :	Sponge	
	Measured position amount :	14	
Measured quantity	L _{WA,indoors} (dB(A))	L _{WA,outdoors} (dB(A))	Remark
Sound pressure level $\hat{L}_{p(ST)}$ ****	--	40	--
Measurement distance d *	--	1.0m	--
Sound power level L _{WA} ****	--	54	--
Setting of controls: according to user manual.			
Duct connection:--			
Rounding to: *) 1 decimal places; **) 2 decimal places; ***) 3 decimal places; ****) nearest integer			



Appendix I Test results

Table 8a.	Sound power level measurement (Low temperature application)		P
Model	CGK-040V4P-B		
	Product type :	Air to Water	
	Outdoor heat exchanger, Air temperature DB/WB (°C):	7.0 / 6.0	
	Indoor heat exchanger, Water outlet temperature (°C):	35.0	
	Voltage (V):	400	
	Frequency (Hz):	50	
	Working condition class :	Class A	
	Acoustical environment :	Hemi-anechoic room	
	Windshield type :	Sponge	
	Measured position amount :	14	
Measured quantity	L _{WA,indoors} (dB(A))	L _{WA,outdoors} (dB(A))	Remark
Sound pressure level ` L _{p(ST)} ****	--	43	--
Measurement distance d *	--	1.0m	--
Sound power level L _{WA} ****	--	57	--
Setting of controls: according to user manual.			
Duct connection:--			
Rounding to: *) 1 decimal places; **) 2 decimal places; ***) 3 decimal places; ****) nearest integer			

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix I Test results

Table 8b.	Sound power level measurement (Medium temperature application)		P
Model	CGK-040V4P-B		
	Product type :	Air to Water	
	Outdoor heat exchanger, Air temperature DB/WB (°C):	7.0 / 6.0	
	Indoor heat exchanger, Water outlet temperature (°C):	55.0	
	Voltage (V):	400	
	Frequency (Hz):	50	
	Working condition class :	Class A	
	Acoustical environment :	Hemi-anechoic room	
	Windshield type :	Sponge	
	Measured position amount :	14	
Measured quantity	L _{WA,indoors} (dB(A))	L _{WA,outdoors} (dB(A))	Remark
Sound pressure level $\hat{L}_{p(ST)}$ ****	--	42	--
Measurement distance d *	--	1.0m	--
Sound power level L _{WA} ****	--	56	--
Setting of controls: according to user manual.			
Duct connection:--			
Rounding to: *) 1 decimal places; **) 2 decimal places; ***) 3 decimal places; ****) nearest integer			

Appendix I Test results

Table 9a.	Sound power level measurement (Low temperature application)		P
Model	CGK-050V4P-B		
	Product type :	Air to Water	
	Outdoor heat exchanger, Air temperature DB/WB (°C):	7.0 / 6.0	
	Indoor heat exchanger, Water outlet temperature (°C):	35.0	
	Voltage (V):	400	
	Frequency (Hz):	50	
	Working condition class :	Class A	
	Acoustical environment :	Hemi-anechoic room	
	Windshield type :	Sponge	
	Measured position amount :	14	
Measured quantity	L _{WA,indoors} (dB(A))	L _{WA,outdoors} (dB(A))	Remark
Sound pressure level ` L _{p(ST)} ****	--	45	--
Measurement distance d *	--	1.0m	--
Sound power level L _{WA} ****	--	59	--
Setting of controls: according to user manual.			
Duct connection:--			
Rounding to: *) 1 decimal places; **) 2 decimal places; ***) 3 decimal places; ****) nearest integer			

Appendix I Test results

Table 9b.	Sound power level measurement (Medium temperature application)		P
Model	CGK-050V4P-B		
	Product type :	Air to Water	
	Outdoor heat exchanger, Air temperature DB/WB (°C):	7.0 / 6.0	
	Indoor heat exchanger, Water outlet temperature (°C):	55.0	
	Voltage (V):	400	
	Frequency (Hz):	50	
	Working condition class :	Class A	
	Acoustical environment :	Hemi-anechoic room	
	Windshield type :	Sponge	
	Measured position amount :	14	
Measured quantity	L _{WA,indoors} (dB(A))	L _{WA,outdoors} (dB(A))	Remark
Sound pressure level $\hat{L}_{p(ST)}$ ****	--	46	--
Measurement distance d *	--	1.0m	--
Sound power level L _{WA} ****	--	60	--
Setting of controls: according to user manual.			
Duct connection:--			
Rounding to: *) 1 decimal places; **) 2 decimal places; ***) 3 decimal places; ****) nearest integer			

Appendix I Test results

Table 10.	Clause 4 of EN 14511-4:2022	P
Model:	CGK-030V4P-B	
TEST 1	STARTING TEST (§4.2.1.2 Table 3)	
Requirement: The "lower" starting operating conditions declared by the manufacturer for the heating mode- i.e. T _{air} = -24.87°C, T in water =10.66°C, Flow rate 0.48m ³ /h have been set and obtained. At those conditions, the machine was switched on.		
Observation/ Evaluation: It started without any problem and worked for 30 minutes without showing any warning or alarm. During the test the machine operated in auto mode. No damage was recorded on the machine during and after the test.		
Test Response: Pass		

TEST 2	OPERATING TEST (§4.2.1.2 Table 3)	
Requirement: From the machine "lower" starting conditions - i.e. - the machine was brought to the lower operating conditions declared by the manufacturer for the heating mode- i.e. T _{air} = -24.88 °C, T in water = 52.30 °C, Flow rate 0.48 m ³ /h. Once these conditions were obtained, the machine was let operate for over 1 hour in auto mode.		
Observation/ Evaluation: During the test, no warning or alarm were showed. No damage was recorded on the machine during and after the test.		
Test Response: Pass		

TEST 3	SHUTTING OFF WATER FLOW (§ 4.5)	
Requirement: The water flow rate was shutted off through manual and automatic valves of the test rig. The machine switched off and only the flow switch Protection appeared on the user interface of indoor unit.		
Observation/ Evaluation: Perform error reset operation, once the water flow rate was restored, the machine restarted automatically and worked for 30 minutes normally. No damage was recorded on the machine during and after the test.		
Test Response: Pass		

TEST 4	SHUTTING OFF AIR FLOW (§ 4.5)	
Requirement: The air flow rate was shutted off through a plastic sheet and a panel. The machine never turned off. It continued to operate with continuous frosting and defrosting cycles. After more than half an hour, the air flow rate was restored and the machine started to operate normally.		
Observation/ Evaluation: During the test, no warning or alarm were showed. No damage was recorded on the machine during and after the test.		
Test Response: Pass		

TEST 5	COMPLETE POWER SUPPLY FAILURE (§ 4.6)	
Requirement: The power supply was cut off for about 5 seconds.		
Observation/ Evaluation: The unit restarted automatically within about 3 minutes after the power supply was reactivated.		
Test Response: Pass		

Doc No.: ITC-TTW0902.02E – Rev.15



Appendix I Test results

Table 11.	Clause 4 of EN 14511-4:2022	P
Model:	CGK-040V4P-B	
TEST 1	STARTING TEST (§4.2.1.2 Table 3)	
Requirement: The "lower" starting operating conditions declared by the manufacturer for the heating mode- i.e. Tair= -24.98°C, T in water =9.87°C, Flow rate 0.63m³/h have been set and obtained. At those conditions, the machine was switched on.		
Observation/ Evaluation: It started without any problem and worked for 30 minutes without showing any warning or alarm. During the test the machine operated in auto mode. No damage was recorded on the machine during and after the test.		
Test Response: Pass		

TEST 2	OPERATING TEST (§4.2.1.2 Table 3)	
Requirement: From the machine "lower" starting conditions - i.e. - the machine was brought to the lower operating conditions declared by the manufacturer for the heating mode- i.e. Tair= -24.97 °C, T in water = 51.71 °C, Flow rate 0.63 m³/h. Once these conditions were obtained, the machine was let operate for over 1 hour in auto mode.		
Observation/ Evaluation: During the test, no warning or alarm were showed. No damage was recorded on the machine during and after the test.		
Test Response: Pass		

TEST 3	SHUTTING OFF WATER FLOW (§ 4.5)	
Requirement: The water flow rate was shutted off through manual and automatic valves of the test rig. The machine switched off and only the flow switch Protection appeared on the user interface of indoor unit.		
Observation/ Evaluation: Perform error reset operation, once the water flow rate was restored, the machine restarted automatically and worked for 30 minutes normally. No damage was recorded on the machine during and after the test.		
Test Response: Pass		

TEST 4	SHUTTING OFF AIR FLOW (§ 4.5)	
Requirement: The air flow rate was shutted off through a plastic sheet and a panel. The machine never turned off. It continued to operate with continuous frosting and defrosting cycles. After more than half an hour, the air flow rate was restored and the machine started to operate normally.		
Observation/ Evaluation: During the test, no warning or alarm were showed. No damage was recorded on the machine during and after the test.		
Test Response: Pass		

TEST 5	COMPLETE POWER SUPPLY FAILURE (§ 4.6)	
Requirement: The power supply was cut off for about 5 seconds.		
Observation/ Evaluation: The unit restarted automatically within about 3 minutes after the power supply was reactivated.		
Test Response: Pass		

Doc No.: ITC-TTW0902.02E – Rev.15



Appendix I Test results

Table 12.	Clause 4 of EN 14511-4:2022	P
Model:	CGK-050V4P-B	
TEST 1	STARTING TEST (§4.2.1.2 Table 3)	
Requirement: The "lower" starting operating conditions declared by the manufacturer for the heating mode- i.e. Tair= -24.88°C, T in water =10.01°C, Flow rate 0.90m³/h have been set and obtained. At those conditions, the machine was switched on.		
Observation/ Evaluation: It started without any problem and worked for 30 minutes without showing any warning or alarm. During the test the machine operated in auto mode. No damage was recorded on the machine during and after the test.		
Test Response: Pass		

TEST 2	OPERATING TEST (§4.2.1.2 Table 3)	
Requirement: From the machine "lower" starting conditions - i.e. - the machine was brought to the lower operating conditions declared by the manufacturer for the heating mode- i.e. Tair= -24.88 °C, T in water = 51.10 °C, Flow rate 0.90 m³/h. Once these conditions were obtained, the machine was let operate for over 1 hour in auto mode.		
Observation/ Evaluation: During the test, no waring or alarm were showed. No damage was recorded on the machine during and after the test.		
Test Response: Pass		

TEST 3	SHUTTING OFF WATER FLOW (§ 4.5)	
Requirement: The water flow rate was shuted off through manual and automatic valves of the test rig. The machine switched off and only the flow switch Protection appeared on the user interface of indoor unit.		
Observation/ Evaluation: Perform error reset operation, once the water flow rate was restored, the machine restarted automatically and worked for 30 minutes normally. No damage was recorded on the machine during and after the test.		
Test Response: Pass		

TEST 4	SHUTTING OFF AIR FLOW (§ 4.5)	
Requirement: The air flow rate was shutted off through a plastic sheet and a panel. The machine never turned off. It continued to operate with continuous frosting and defrosting cycles. After more than half an hour, the air flow rate was restored and the machine started to operate normally.		
Observation/ Evaluation: During the test, no waring or alarm were showed. No damage was recorded on the machine during and after the test.		
Test Response: Pass		



TEST 5	COMPLETE POWER SUPPLY FAILURE (§ 4.6)	
Requirement: The power supply was cut off for about 5 seconds.		
Observation/ Evaluation: The unit restarted automatically within about 3 minutes after the power supply was reactivated.		
Test Response: Pass		

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix II Marking plate

Nameplate

Model: CGK-030V4P-B




SPRSUN		
DC Inverter Air Source Heat Pumps		
Model	CGK-030V4P-B	
Power Supply	380-420V 3N~/50Hz	
*Heating Capacity Min./Max.	3.15/9.1kW	
*Heating Input Power Min./Max.	0.63/2.17kW	
*Heating COP Min./Max.	4.20/5.0W/W	
Cooling Capacity Min./Max.	2.10/5.63kW	
Cooling Input Power Min./Max.	0.61/2.12kW	
Rated Input Power/Current	4.0kW/8.44A	
Max. Water Outlet Temperature	75°C	
Max. Water Pump Flow	4m ³ /h	
Max. Water Pump Head	9m	
Rated Water Flow	1.55m ³ /h	
Refrigerant/Weight		R290/0.75kg
Low/High side operation pressure	0.85/3.2MPa	
Low/High maximum allowable pressure	1.8/3.2MPa	
Max Water Pressure	1.0MPa	
Shock Proof Grade	I	
Water Proof Level	IPX4	
Water Pressure Drop	20kPa	
Water Pipe Connection	1 inch	
Net Weight	106kg	
Date/NO.	See bar code	
System CO2 equivalent charge weight : 0.0024 ton		
*Heating working condition:		
Dry bulb temperature 7°C , Wet bulb temperature 6°C		
Inlet water temperature 30°C, Outlet water temperature 35°C		
Guangzhou Sprsun New Energy Technology Development Co., Ltd No. 15 Tangxi Road, Yinsha Industrial Park, Xintang, Zengcheng Guangzhou, China		

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix II Marking plate

Nameplate

Model: CGK-040V4P-B



SPRSUN		 
DC Inverter Air Source Heat Pumps		
Model	CGK-040V4P-B	
Power Supply	380-420V 3N~/50Hz	
*Heating Capacity Min./Max.	4.35/12kW	
*Heating Input Power Min./Max.	0.89/3.07kW	
*Heating COP Min./Max.	3.9/4.92W/W	
Cooling Capacity Min./Max.	3.58/7.2kW	
Cooling Input Power Min./Max.	1.21/2.75kW	
Rated Input Power/Current	5.0kW/23.92A	
Max. Water Outlet Temperature	75°C	
Max. Water Pump Flow	4m ³ /h	
Max. Water Pump Head	9m	
Rated Water Flow	2.06m ³ /h	
Refrigerant/Weight		R290/0.90kg
Low/High side operation pressure	0.85/3.2MPa	
Low/High maximum allowable pressure	1.8/3.2MPa	
Max Water Pressure	1.0MPa	
Shock Proof Grade	I	
Water Proof Level	IPX4	
Water Pressure Drop	21kPa	
Water Pipe Connection	1 inch	
Net Weight	110kg	
Date/NO.	See bar code	
System CO2 equivalent charge weight : 0.003 ton		
*Heating working condition:		
Dry bulb temperature 7°C , Wet bulb temperature 6°C		
Inlet water temperature 30°C, Outlet water temperature 35°C		
Guangzhou Sprsun New Energy Technology Development Co., Ltd No. 15 Tangxi Road, Yinsha Industrial Park, Xintang, Zengcheng Guangzhou, China		

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix II Marking plate


Nameplate

Model: CGK-050V4P-B

SPRSUN		
DC Inverter Air Source Heat Pumps		
Model	CGK-050V4P-B	
Power Supply	380-420V 3N~/50Hz	
*Heating Capacity Min./Max.	5.6/15kW	
*Heating Input Power Min./Max.	1.13/3.8kW	
*Heating COP Min./Max.	3.94/4.96W/W	
Cooling Capacity Min./Max.	4.69/10.2kW	
Cooling Input Power Min./Max.	1.52/3.88kW	
Rated Input Power/Current	6.3kW/13.29A	
Max. Water Outlet Temperature	75°C	
Max. Water Pump Flow	6.2m ³ /h	
Max. Water Pump Head	10.5m	
Rated Water Flow	2.6m ³ /h	
Refrigerant/Weight 	R290/1.2kg	
Low/High side operation pressure	0.85/3.2MPa	
Low/High maximum allowable pressure	1.8/3.2MPa	
Max Water Pressure	1.0MPa	
Shock Proof Grade	I	
Water Proof Level	IPX4	
Water Pressure Drop	23kPa	
Water Pipe Connection	1 inch	
Net Weight	135kg	
Date/NO.	See bar code	
System CO2 equivalent charge weight : 0.0036 ton		
*Heating working condition:		
Dry bulb temperature 7°C , Wet bulb temperature 6°C		
Inlet water temperature 30°C, Outlet water temperature 35°C		
Guangzhou Sprsun New Energy Technology Development Co., Ltd No. 15 Tangxi Road, Yinsha Industrial Park, Xintang, Zengcheng Guangzhou, China		

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix III photo documentation


Details of:	Overall view for CGK-030V4P-B
View:	
<input type="checkbox"/> General <input type="checkbox"/> Front <input type="checkbox"/> Rear <input type="checkbox"/> Right <input type="checkbox"/> Left <input type="checkbox"/> Top <input type="checkbox"/> Bottom	

Details of:	Compressor for CGK-030V4P-B
View:	
<input type="checkbox"/> General <input type="checkbox"/> Front <input type="checkbox"/> Rear <input type="checkbox"/> Right <input type="checkbox"/> Left <input type="checkbox"/> Top <input type="checkbox"/> Bottom	

Doc No.: ITC-TTW0902.02E – Rev.15


Appendix III photo documentation


Details of:	Fan Motor for CGK-030V4P-B
<p>View:</p> <p><input type="checkbox"/> General</p> <p><input type="checkbox"/> Front</p> <p><input type="checkbox"/> Rear</p> <p><input type="checkbox"/> Right</p> <p><input type="checkbox"/> Left</p> <p><input type="checkbox"/> Top</p> <p><input type="checkbox"/> Bottom</p>	 <p>The photograph shows a white label for a BLDC motor. The label contains the following information: <ul style="list-style-type: none"> Brand: MW (Match-Well) Product Name: 永磁无刷直流电动机 (BLDC Motor) Model: MWS116-8K-PD1 Specifications: DC310V 116W, 900r/min B CL. 8P Company: 江苏曼淇威电气产品有限公司 (Jiangsu Match-Well Electrical Products Co., Ltd.) Wiring Diagram: A diagram showing a motor symbol 'M' connected to five terminals: VCC (Red), GND (Black), VCC (White), VSP (Yellow), and FG (Blue). Rotation: An arrow labeled 'ROT' points to the left. Certification: A CCC (China Compulsory Certification) mark is visible. </p>

Details of:	Main Control Board for CGK-030V4P-B
<p>View:</p> <p><input type="checkbox"/> General</p> <p><input type="checkbox"/> Front</p> <p><input type="checkbox"/> Rear</p> <p><input type="checkbox"/> Right</p> <p><input type="checkbox"/> Left</p> <p><input type="checkbox"/> Top</p> <p><input type="checkbox"/> Bottom</p>	 <p>The photograph shows the internal main control board of the device. It features a green PCB populated with various electronic components including integrated circuits, capacitors, and resistors. Numerous colored wires (red, blue, yellow, black) are connected to the board, some using terminal blocks. The board is housed within a white metal enclosure.</p>

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix III photo documentation


Details of:	Water Pump for CGK-030V4P-B
View:	
<input type="checkbox"/> General	
<input type="checkbox"/> Front	
<input type="checkbox"/> Rear	
<input type="checkbox"/> Right	
<input type="checkbox"/> Left	
<input type="checkbox"/> Top	
<input type="checkbox"/> Bottom	

Details of:	Overall view for CGK-040V4P-B
View:	
<input type="checkbox"/> General	
<input type="checkbox"/> Front	
<input type="checkbox"/> Rear	
<input type="checkbox"/> Right	
<input type="checkbox"/> Left	
<input type="checkbox"/> Top	
<input type="checkbox"/> Bottom	

Doc No.: ITC-TTW0902.02E – Rev.15


Appendix III photo documentation


Details of:	Compressor for CGK-040V4P-B
View:	
<input type="checkbox"/> General	
<input type="checkbox"/> Front	
<input type="checkbox"/> Rear	
<input type="checkbox"/> Right	
<input type="checkbox"/> Left	
<input type="checkbox"/> Top	
<input type="checkbox"/> Bottom	

Details of:	Fan Motor for CGK-040V4P-B
View:	
<input type="checkbox"/> General	
<input type="checkbox"/> Front	
<input type="checkbox"/> Rear	
<input type="checkbox"/> Right	
<input type="checkbox"/> Left	
<input type="checkbox"/> Top	
<input type="checkbox"/> Bottom	

Doc No.: ITC-TTW0902.02E - Rev.15


Appendix III photo documentation

Details of:	Main Control Board for CGK-040V4P-B
View:	
<input type="checkbox"/> General	
<input type="checkbox"/> Front	
<input type="checkbox"/> Rear	
<input type="checkbox"/> Right	
<input type="checkbox"/> Left	
<input type="checkbox"/> Top	
<input type="checkbox"/> Bottom	

Details of:	Water Pump for CGK-040V4P-B
View:	
<input type="checkbox"/> General	
<input type="checkbox"/> Front	
<input type="checkbox"/> Rear	
<input type="checkbox"/> Right	
<input type="checkbox"/> Left	
<input type="checkbox"/> Top	
<input type="checkbox"/> Bottom	

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix III photo documentation


Details of:	Overall view for CGK-050V4P-B
<p>View:</p> <p><input type="checkbox"/> General</p> <p><input type="checkbox"/> Front</p> <p><input type="checkbox"/> Rear</p> <p><input type="checkbox"/> Right</p> <p><input type="checkbox"/> Left</p> <p><input type="checkbox"/> Top</p> <p><input type="checkbox"/> Bottom</p>	

Details of:	Compressor for CGK-050V4P-B
<p>View:</p> <p><input type="checkbox"/> General</p> <p><input type="checkbox"/> Front</p> <p><input type="checkbox"/> Rear</p> <p><input type="checkbox"/> Right</p> <p><input type="checkbox"/> Left</p> <p><input type="checkbox"/> Top</p> <p><input type="checkbox"/> Bottom</p>	

Doc No.: ITC-TTW0902.02E – Rev.15


Appendix III photo documentation

Details of:	Fan Motor for CGK-050V4P-B
<p>View:</p> <p><input type="checkbox"/> General</p> <p><input type="checkbox"/> Front</p> <p><input type="checkbox"/> Rear</p> <p><input type="checkbox"/> Right</p> <p><input type="checkbox"/> Left</p> <p><input type="checkbox"/> Top</p> <p><input type="checkbox"/> Bottom</p>	 <p>The photograph shows a white label for a BLDC motor. The label contains the following information: <ul style="list-style-type: none"> Brand: MW (Match-Well) Product Name: 永磁无刷直流电动机 (BLDC Motor) Model: MWS116-8K-PD1 Specifications: DC310V 116W, 900r/min B CL. 8P Company: 江苏曼淇威电气产品有限公司 (Jiangsu Match-Well Electrical Products Co., Ltd.) Wiring Diagram: A diagram showing a motor symbol 'M' connected to five wires: VCC (Red), GND (Black), VSP (White), VFP (Yellow), and FG (Blue). Rotation: An arrow labeled 'ROT' points to the left. Certification: A CCC (China Compulsory Certification) mark is visible. </p>

Details of:	Main Control Board for CGK-050V4P-B
<p>View:</p> <p><input type="checkbox"/> General</p> <p><input type="checkbox"/> Front</p> <p><input type="checkbox"/> Rear</p> <p><input type="checkbox"/> Right</p> <p><input type="checkbox"/> Left</p> <p><input type="checkbox"/> Top</p> <p><input type="checkbox"/> Bottom</p>	 <p>The photograph shows the internal components of a main control board. It features a green printed circuit board (PCB) populated with various electronic components, including integrated circuits, capacitors, and resistors. Numerous colored wires (red, blue, yellow, black) are connected to the board, some bundled together. The board is housed within a metal enclosure, and the overall setup is complex and densely packed.</p>

Doc No.: ITC-TTW0902.02E - Rev.15

Appendix III photo documentation

Details of:	Water Pump for CGK-050V4P-B
<p>View:</p> <p><input type="checkbox"/> General</p> <p><input type="checkbox"/> Front</p> <p><input type="checkbox"/> Rear</p> <p><input type="checkbox"/> Right</p> <p><input type="checkbox"/> Left</p> <p><input type="checkbox"/> Top</p> <p><input type="checkbox"/> Bottom</p>	

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix IV Construction data form

Model: CGK-030V4P-B		
Part		Technical data
1. Compressor		
	Manufacture:	Shanghai Highly Electrical Appliance Co., Ltd.
	Type:	WHP07600PSDPC9KQ
	Serial-number:	20231H0001572
	Specification:	R290
2. Condenser		
	Manufacture:	Jiangsu Yuanzhuo Equipment Manufactur Co.,Ltd
	Type:	ZL62FA-26AD-CG
	Heat exchanger:	Plate heat exchanger
	Dimension(mm):	526(L)mmX119(H)mmX63(D)mm
3. Evaporator		
	Manufacture:	Guangzhou Aotai Refrigeration EquipmentCo.,Ltd.
	Type:	03KK-CP-01
	Heat exchanger:	Finned-coil heat exchanger
	Dimension(mm):	660.4(L)mmX764(H)mmX356.8(D)mm
4. Fan motor		
	Manufacture:	Jiangsu Match-Well Electrical Products Co., Ltd.
	Type:	MWS116-8K-PD1
	Fan type:	3 blade
	Specification:	DC310V; 116W
5. Main control board		
	Manufacture:	Guangdong Chico Electronic Inc.
	Type:	CG248075
	Specification:	220-240V~; 50Hz
6. Water pump		
	Manufacture:	SHIMGE PUMP INDUSTRY(JIANGSU)CO.,LTD.
	Type:	APM25-9-130S PWM1
	Specification:	230V~; 50/60Hz
*(Alternative)		
	Manufacture:	Shinhoo
	Type:	GPA25-9HW
	Specification:	230V~; 50Hz

Remark: * means the test results were not performed on the alternative components.

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix IV Construction data form

Model: CGK-040V4P-B		
Part		Technical data
1. Compressor		
	Manufacture:	Shanghai Highly Electrical Appliance Co., Ltd.
	Type:	WHP10200PSDPC9KQ
	Serial-number:	W7XN5H08KB6J
	Specification:	DC143.5V; R290
2. Condenser		
	Manufacture:	Jiangsu Yuanzhuo Equipment Manufactur Co.,Ltd
	Type:	ZL62FA-30AD-CG
	Heat exchanger:	Plate heat exchanger
	Dimension(mm):	526(L)mmX119(H)mmX71(D)mm
3. Evaporator		
	Manufacture:	Guangzhou Aotai Refrigeration EquipmentCo.,Ltd.
	Type:	04KK-CP-01
	Heat exchanger:	Finned-coil heat exchanger
	Dimension(mm):	675.4(L)mmX914(H)mmX356.8(D)mm
4. Fan motor		
	Manufacture:	Jiangsu Match-Well Electrical Products Co., Ltd.
	Type:	MWS116-8K-PD1
	Fan type:	3 blade
	Specification:	DC310V; 116W
5. Main control board		
	Manufacture:	Guangdong Chico Electronic Inc.
	Type:	CG248075
	Specification:	220-240V~; 50Hz
6. Water pump		
	Manufacture:	SHIMGE PUMP INDUSTRY(JIANGSU)CO.,LTD.
	Type:	APM25-9-130S PWM1
	Specification:	230V~; 50/60Hz
*(Alternative)		
	Manufacture:	Shinhoo
	Type:	GPA25-9HW
	Specification:	230V~; 50Hz

Remark: * means the test results were not performed on the alternative components.

Doc No.: ITC-TTW0902.02E – Rev.15

Appendix IV Construction data form

Model: CGK-050V4P-B		
Part		Technical data
1. Compressor		
	Manufacture:	Shanghai Highly Electrical Appliance Co., Ltd.
	Type:	WHP13300PSDPC8FQ
	Serial-number:	20231H0002839
	Specification:	DC143.5V; R290
2. Condenser		
	Manufacture:	Jiangsu Yuanzhuo Equipment Manufactur Co.,Ltd
	Type:	ZL62FA-40AD-CG
	Heat exchanger:	Plate heat exchanger
	Dimension(mm):	526(L)mmX119(H)mmX91(D)mm
3. Evaporator		
	Manufacture:	Guangzhou Aotai Refrigeration EquipmentCo.,Ltd.
	Type:	05KK-CP-01
	Heat exchanger:	Finned-coil heat exchanger
	Dimension(mm):	660.4(L)mmX1318.5(H)mmX356.8(D)mm
4. Fan motor		
	Manufacture:	Jiangsu Match-Well Electrical Products Co., Ltd.
	Type:	MWS116-8K-PD1
	Fan type:	3 blade
	Specification:	DC310V; 116W
5. Main control board		
	Manufacture:	Guangdong Chico Electronic Inc.
	Type:	CG248075
	Specification:	220-240V~; 50Hz
6. Water pump		
	Manufacture:	SHIMGE PUMP INDUSTRY(JIANGSU)CO.,LTD.
	Type:	APF25-12-130E FPWM1
	Specification:	230V~; 50/60Hz
*(Alternative)		
	Manufacture:	Shinhoo
	Type:	GPA25-11H
	Specification:	230V~; 50Hz

Remark: * means the test results were not performed on the alternative components.

Doc No.: ITC-TTW0902.02E – Rev.15



Appendix V Equipment List

No.	Type	Manufacture	Model	Equipment ID	Calibration Due Date
1	Heat pump energy efficiency testing system	PINXIN	10HP	2017J00001	2024-11-15
2	Electromagnetic flowmeter	KROHNE	OPTIFLUX4100C	H17221264	2024-11-19
3	Hemi-anechoic room(B)	Guangzhou Kinte	5.2m×4.4m×4.6m	NC-036-3	2028-10-06
4	Dynamic signal analysis system	—	HAHI2022	VG DY-2137	2025-01-08
5	Calibrator	B & K	4231	HJ-000095	2024-07-06
6	AC source Supply	YANGHONG	AFC-33030TS	VGDS-0637	2024-11-02
7	Long steel tape	—	5m	HJ-000062	2024-09-11
8	Temperature measurement system	—	Special	NC-036-1	2025-06-03
9	Atmospheric pressure meter	—	—	HJ-000165	2024-11-21
10	Constant temperature water system	B & K	Special	VGDS-0448	2025-04-12
11	Windscreen	B & K	WS002-5	—	—

-- End of Report --